

Ashford Borough Council
Development Control

Our ref: KT/2025/132282/01-L01
Your ref: NOT/2025/0113

Sent via email

Date: 29 January 2025

Dear Planning Team

Prior approval for the change of use of an agricultural building and land within its curtilage to a single-storey dwelling house and associated operational development

Existing Building , Barnfield Road, Charing , TN27 0BN

Thank you for consulting us on the above application which we received on 23 January 2025.

Environment Agency position

In the absence of a flood risk assessment (FRA), we **object** to this application and recommend that planning permission is refused.

Please refer to the following sections below for our full response:

Please note that our comments are based on the details available to us at the time of writing. If any subsequent changes are made to the application, please reconsult us.

Should you have any queries regarding this response, please contact me.

Yours faithfully

Ms Jennifer Wilson
Planning Specialist

Direct e-mail kslplanning@environment-agency.gov.uk

Section 1: Reasons for, and how to overcome, our objection

Flood Risk

The application site lies within Flood Zone 3 and Flood Zone 2, which is land defined by the planning practice guidance as having a high and medium probability of flooding retrospectively. The National Planning Policy Framework (paragraph 181, footnote 63) states that an FRA must be submitted when development is proposed in such locations. Only the northeastern area of the site is located within Flood Zone 1.

An FRA is vital to making informed planning decisions. In its absence, the flood risks posed by the development are unknown. This is sufficient reason for refusing planning permission.

To overcome our objection, the applicant should submit an FRA which demonstrates that the development is safe without increasing risk elsewhere. Where possible, it should reduce flood risk overall.

If this cannot be achieved, we are likely to maintain our objection. Please re-consult us on any revised FRA submitted and we'll respond within 21 days of receiving it.

Guidance on how to prepare a flood risk assessment can be found at <https://www.gov.uk/guidance/flood-risk-assessment-for-planning-applications>.

Section 2: Advice to the Applicant

Advice to applicant

Connection to mains foul drainage

Government guidance contained within the national Planning Practice Guidance (Water supply, wastewater and water quality – considerations for planning applications, paragraph 020) sets out a hierarchy of drainage options that must be considered and discounted in the following order:

- Connection to the public sewer
- Package sewage treatment plant (adopted in due course by the sewerage company or owned and operated under a new appointment or variation)
- Septic Tank

Foul drainage should be connected to the main sewer. Where this is not possible, under the Environmental Permitting Regulations 2016 any discharge of sewage or trade effluent made to either surface water or groundwater will need to be registered as an exempt discharge activity or hold a permit issued by the Environment Agency, additional to planning permission. This applies to any discharge to inland freshwaters, coastal waters or relevant territorial waters.

Please note that the granting of planning permission does not guarantee the granting of an Environmental Permit. Upon receipt of a correctly filled in application form we will carry out an assessment. It can take up to 4 months before we are in a position to decide whether to grant a permit or not.

Domestic effluent discharged from a treatment plant/septic tank at 2 cubic metres or less to ground or 5 cubic metres or less to surface water in any 24-hour period must comply with General Binding Rules provided that no public foul sewer is available to serve the development and that the site is not within an inner Groundwater Source Protection Zone.

A soakaway used to serve a non-mains drainage system must be sited no less than 10 metres from the nearest watercourse, not less than 10 metres from any other foul soakaway and not less than 50 metres from the nearest potable water supply.

Where the proposed development involves the connection of foul drainage to an existing non-mains drainage system, the applicant should ensure that it is in a good state of repair, regularly de-sludged and of sufficient capacity to deal with any potential increase in flow and loading which may occur as a result of the development.

Where the existing non-mains drainage system is covered by a permit to discharge then an application to vary the permit will need to be made to reflect the increase in volume being discharged. It can take up to 13 weeks before we decide whether to vary a permit.

Further advice is available at: [Septic tanks and treatment plants: permits and general binding rules.](#)

Note to applicant

Planning advice service

Should you wish us to review any technical documents or want further advice to address the environmental issues raised, we may do this as part of our charged for planning advice service.

Further engagement will provide you with the opportunity to discuss and gain our views on potential options to overcome our objection with us, before formally submitting further information as part of your planning application and certainty of our position as to what our response to your planning application will be. It should also result in a better quality and more environmentally sensitive development.

As part of our charged for service we will provide a dedicated project manager to act as a single point of contact to help resolve any problems. We currently charge £100 per hour, plus VAT. We will provide you with an estimated cost for any further discussions or review of documents. The standard terms of our charged for service are available [here](#).

If you would like more information on our planning advice service, including a cost estimate, please contact us at kslplanning@environment-agency.gov.uk